

Unidad 15



Introduction to solar PV energy - Dimensioning -

**Alberto Escudero-Pascual, IT+46
(cc) Creative Commons Share-Alike
Non Commercial Attribution 2.5 Sweden**

The power of the sun - G



- ◆ Global Irradiation 0.29-0.4 μm
- ◆ Instantaneous value (Power) W/m^2
- ◆ Units
 - ✓ Energy: Wh/m^2
 - ✓ Energy: J/m^2
 - ✓ Solar Peak Hours
- ◆ Conversions
 - ✓ 1 wh = 3600 J
- ◆ Irradiance (W) vs Irradiation (Wh)

G



- ♦ Irradiance and irradiation values stand for area densities, i.e. no subscripts are used to indicate the surface area. All symbols refer to horizontal planes; for a tilted plane, the slope β and the plane azimuth (Alpha) are added in brackets.
- ♦ Subscript 0 stands for extraterrestrial or astronomical.
- ♦ Subscript h stands for hourly and subscript d for daily.

The figures



- ♦ A nearly constant 1.36 kilowatts per square meter (the solar constant) of solar radiant power impinges on the earth's outer atmosphere.
- ♦ Approximately 70% of this extraterrestrial radiation makes it through our atmosphere on a clear day.
- ♦ Irradiance at ground level regularly exceeds 1,000 w/m². In some mountain areas, readings over 1,200 w/m² are often recorded.

Type of systems



- ◆ Grid-Intertied solar-electric system: on grid
 - ◆ Grid-Intertied solar-electric system with battery backup
 - ◆ Off-Grid solar-electric system with battery backup (Telcenter A)
 - ◆ Grid-Intertied solar-electric system with battery and generator backup (Telecenter B)
-

Type of load



- ◆ AC load
 - ◆ DC load
 - ◆ Direct pump (no batteries)
-

Components (I)



- ◆ PV
 - ◆ PV Mounts
 - ◆ Array PV - DC Disconnect
 - ◆ Charge Controller (Regulator)
 - ◆ Battery
-

Components (II)



- ◆ System Meter
 - ◆ Main DC Disconnect
 - ◆ Inverter
 - ◆ AC Breaker Panel (AC Disconnect)
 - ◆ Kwh meter (Utility Meter)
-

PV Panel



- ◆ Isc
 - ◆ Voc
 - ◆ I_{pmax} , V_{pmax} (Maximum Power)
 - ◆ Voltage is enforced by the battery
 - ◆ Form Factor ($P_{max}/I_{sc} \cdot V_{sc}$) 0.7-0.8
-

PV Panel



- ◆ Performance: $P_{\max}/P_{\text{sun}} \sim 10\%-13\%$
- ◆ Normalized conditions $1\text{kW}/\text{m}^2$ sea level 25 C
- ◆ W_p (Peak Power)

Testing the panels



- ♦ Testing the panels (annex)
-

PV Panel



- ◆ Operation:
 - ✓ I_{pmax} , V_{max}
 - ✓ Efficiency Lost: $P_{max} - 5\%$
- ◆ Array
 - ✓ Same panels
 - ✓ Serial = We add V
 - ✓ Parallel = We get more I

Battery



- ◆ Serial elements: 2 V
- ◆ Models: 12 V, 24 V and 48 V
- ◆ Car batteries vs Deep Cycle Batteries
 - ✓ 1.2 to 1.28 (add water)

Deep Cycle Batteries



- ◆ Nickel-Cadmium (vs) Lead-Acid
- ◆ Maintenance vs Cost

Sun and Battery Cycles



- ◆ Daily
 - ◆ Seasons
 - ◆ Weather
-

Battery Status



- ◆ Over charged
 - ✓ Gas, oxidation of positive eletrod
 - ✓ Reduces acid stratification
 - ✓ Controlled 2.35 – 2.4 V
 - ✓ Role of regulator
 - ◆ Over discharged
 - ✓ Lower limit 1.85
 - ✓ PbSo4 Lead Sulfate
-

Battery Parameters



- ◆ Vn Nominal Voltage
- ◆ Cn Nominal Capacity Ah, Wh
- ◆ C100
- ◆ SOC vs DOD
- ◆ DOD 70% and life of the battery
- ◆ Cusable = $C_n * MDR$ (maximum discharge rate)

Temp and Batteries



- ◆ Capacity 1%/C
 - ◆ Low temperatures – Battery charge to avoid freeze (reduce the max. discharge rate)
-

Loads



- ◆ Role of low power devices
 - ◆ Energy Demands
 - ✓ Estimation
 - ✓ Forecasting
 - ◆ User Habits
-

Regulator



- ◆ Cuts at 2.45 V (battery state)
 - ◆ Maximum current (at least 20% more than the PV)
 - ◆ Operating tension
-

Regulator



- ◆ Serial (can disconnect) vs Shunt (NO!)
- ◆ Charge Controller
 - ✓ Senses Temp of Batteries Battery Temperature Compensation (BTC)
 - ✓ Can lower the V of the panels to increase the I
 - ✓ PWM (Pulse Width Modulation)
 - ✓ Measures and cuts (LVD) Low voltage disconnect
 - ✓ Maximum Power Point Tracking

Inverter



- ◆ Converter DC/AC
 - ◆ DC/DC (pumps, to start them)
 - ◆ Sin wave vs modified sin wave
 - ◆ Be Careful not all equipment can handle a modified sin wave inverter!
 - ◆ Protection (sc)
 - ◆ Efficiency
-

Inverter Parameters



- ◆ Protection (against sc)
 - ◆ Efficiency $> 70\%$
-

Calculation



- ◆ Method: Worse month
- ◆ Reliable: how many days without sun?
 - ✓ Autonomy days (N)
 - ✓ Nominal Voltage?
 - ◆ More than 3 KW = 48 V

Worse Month



- ♦ What is the worse month?
 - ♦ We need to know the energy demands (DC + AC) and the energy available
 - ♦ What PV array angle is optimal?
-

Orientation



- ◆ Towards the equator
- ◆ Tolerance of 20 degrees (alpha)
- ◆ Angle (β):
 - ✓ $|L| + 10 = \text{winter}$
 - ✓ $|L| = 0$
 - ✓ $|L| - 10 = \text{summer}$
- ◆ Angle > 20 degrees (dust)

$G(\beta, r, \text{Lat})$



- ◆ Daily or monthly average energy at angle B
- ◆ $G(B) = f(G(0))$
- ◆ $f(B) = AG(0) + B(G(0))^2$
- ◆ A depends on $r=0.2$ and β
- ◆ B depends on Latitude and β
- ◆ We can always use a simulation tool to get the values!

Imax (Loads)



- ◆ $E_t = E(AC) + E(DC)$ (Ah) (electric charge)
- ◆ Ah/day - Ah/period
- ◆ $G(B) = \text{Kwh/m}^2 \text{ day}$
- ◆ $I_{max} = E_t / G(B)$
- ◆ Example
 - ✓ Nigeria = 3.5 – 4 Kwh.m² day
 - ✓ $E_t = 100 \text{ Ah}$
 - ✓ $I_{max} = 25 \text{ A/Kw} * \text{m}^2$

Number of par. panels?



- ◆ $N_{pp} = I_{max}/I_{pmax}$
 - ◆ Example
 - ✓ $25 \text{ A/kw.m}^2 / 5 \text{ A/kw.m}^2 = 5 \text{ Units}$
-

Capacity of Battery?



- ◆ Normally measure in Ah (electric charge)
- ◆ Serie vs Parallel
- ◆ Example:
 - ✓ $C_{100} = 200 \text{ Ah}$
 - ✓ Usable = $200 \text{ Ah} \times \text{discharge depth (70\%)} = 140 \text{ Ah}$
- ◆ Dimensioning
 - ✓ Capacity = $N. Et (\text{Ah}) * 1.2$

Regulator and Inverter Power



- ◆ Regulator
 - ✓ $20\% I_{max} \times N_{pp}$
- ◆ Inverter
 - ✓ Performance at 70% of the load

Conclusion



- ◆ Multi-variable system
 - ◆ Simulation: Worst month
 - ◆ Set pre-conditions first
 - ◆ Measure your load
 - ✓ Are there any possible energy savings?
 - ◆ Be careful with the units!
-